

PROVIDE 1'-6" SQ. BY 4" THICK  
CONCRETE PAD, IF SPECIFIED.




## Cover Plan East Jordan

HAND TAMP BACKFILL  
AROUND TOP SECTION

AWWA C509  
RESILIENT SEATED  
EPOXY COATED  
NRS  
2" SQUARE OPERATING NUT/LEFT TURN

### ACCEPTABLE VALVES:

CLOW  
KENNEDY KEN - SEAL II  
M & H STYLE 4067  
US PIPE METROSEAL 250  
MUELLER A-2360  
AMERICAN 2500



GRIND OFF WORDS  
"PORTLAND OR."

## Cover Plan Olympic Foundry

LENGTH AS REQUIRED  
8" INCH PVC ONLY

GATE VALVE

MAIN

VALVE SIZE AND TYPE  
AS SPECIFIED OR SHOWN  
ON PLANS.

### NOTES:

1. ORDER MJ GATE VALVES WITHOUT ACCESSORIES
2. PORTLAND WATER BUREAU STANDARD VALVE BOX AND COVER AS MANUFACTURED BY OLYMPIC FOUNDRY:
  - 8" CAST IRON VALVE BOX BODY/PORTLAND STYLE/#5-603A
  - 8" CAST IRON VALVE BOX LID /PORTLAND STYLE/#5-603B
  - GRIND OFF WORDS "PORTLAND OR." LEAVE WORD "WATER".
  - BITUMINOUS COATING ON VALVE BODY + LID.
3. or EAST JORDAN 8-INCH MODEL 00366310-TOP SECTION AND 00366326-COVER